

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surface mounted Socket-outlet

Name and address of the applicant

ALING – CONEL d.o.o.
Železnička 10, 21432 Gajdobra, Serbia

Name and address of the manufacturer

ALING – CONEL d.o.o.
Železnička 10, 21432 Gajdobra, Serbia

Name and address of the factory

ALING – CONEL d.o.o.
Železnička 10, 21432 Gajdobra, Serbia*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2

16 A; 250 V~; IP55

Trademark / Brand (if any)

ALING - CONEL

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

art.2711.xx

Additional information (if necessary may also be reported on page 2)

See the Test Report for information about National Differences.

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

T211-1119/25 (2025-11-14)

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Mašera-Spasičeva ulica 10, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services (SIST EN ISO/IEC 17065).

Date: 2025-11-14

Signature: Matej Žontar

Socket-outlet is part of ARMOR line products. It is surface type socket outlet with plastic main part, where:

xx – color code mark (1A – grey with anthracite cover (lid))

Additional information (if necessary)

This CB certificate replaces previously issued CB certificate SI-6788 issued on 2018-09-12 due to new test report.

Date: 2025-11-14

Signature: Matej Žontar