



Ref. Certif. No.

SI-7264

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surface-mounted installation boxes

Name and address of the applicant

ALING – CONEL d.o.o., Železnička 10, RS-21432
Gajdobra, Serbia

Name and address of the manufacturer

ALING – CONEL d.o.o., Železnička 10, RS-21432
Gajdobra, Serbia

Name and address of the factory

ALING – CONEL d.o.o., Železnička 10, RS-21432
Gajdobra, Serbia

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

☐ Additional Information on page 2

IP55

"see page 2 for additional information"

Trademark (if any)

ALING - CONEL

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

"see page 2"

Additional information (if necessary may also
be reported on page 2)

/

☒ Additional Information on page 2

A sample of the product was tested and found
to be in conformity with

IEC 60670-22:2003 + AMD1:2015; IEC 60670-1:2015

As shown in the Test Report Ref. No. which
forms part of this Certificate

T211-0400/19; dated 2019-05-21

This CB Test Certificate is issued by the National Certification Body



SIQ Ljubljana, Tržaška cesta 2, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the
field of certification of products, processes and services.

Date: 2019-05-21

Signature: Bojan Pečavar



Ref. Certif. No.

SI-7264

Article number	Size	Number of inlets	IP code	Temperature rating
art.71422.x	95 x 90 x 55 mm (2M)	0	IP55	-25°C...+60°C
art.71424.x	140 x 90 x 55 mm (4M)	0	IP55	-25°C...+60°C

x – color code:

0 = white; 1 = grey

Additional information (if necessary)

Date: 2019-05-21

Signature: Bojan Pečavar