

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surface Mounted Installation Box

Name and address of the applicant

ALING – CONEL d.o.o.
Železnička 10, RS-21432 Gajdobra, Serbia

Name and address of the manufacturer

ALING – CONEL d.o.o.
Železnička 10, RS-21432 Gajdobra, Serbia

Name and address of the factory

ALING – CONEL d.o.o.
Železnička 10, RS-21432 Gajdobra, Serbia*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2

500 V~; IP54

Trademark (if any)

POWER LINE

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

art.261.x, 262.x, 263.x
(where x is the color code mark: 0 - white, 1 - gray)

Additional information (if necessary may also be reported on page 2)

see page 2

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-22:2003 (1st Ed.) + A1:2015;
IEC 60670-1:2015 (2nd Ed.)

As shown in the Test Report Ref. No. which forms part of this Certificate

T211-0755/18; dated 2018-10-12

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Tržaška cesta 2, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services.

Date: 2018-10-12

Signature: Bojan Pečavar

Surface mounted installation boxes are of the same construction, but with different number of inlet/outlet grommets:

- art.261.x (3 inlet/outlet grommets)
- art.262.x (4 inlet/outlet grommets)
- art.263.x (6 inlet/outlet grommets)

Additional information (if necessary)

Date: 2018-10-12

Signature: Bojan Pečavar

