

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surface mounted installation switches

Name and address of the applicant

ALING – CONEL d.o.o., Železnička 10, 21432 Gajdobra, Serbia

Name and address of the manufacturer

ALING – CONEL d.o.o., Železnička 10, 21432 Gajdobra, Serbia

Name and address of the factory

ALING – CONEL d.o.o., Železnička 10, 21432 Gajdobra, Serbia

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

☐ Additional Information on page 2

10 AX; 250 V~; IP44

Trademark / Brand (if any)

POWER

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See page 2

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

☒ Additional Information on page 2

IEC 60669-1:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

T211-1078/21 (2021-12-27)

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Mašera-Spasičeva ulica 10, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services.

Date: 2021-12-27

Signature: Bojan Pečavar



List of all models and description:

Model No. / Type reference	Description	Pattern number
art.251.xx	Single pole switch	1
art.252.xx	Two circuit switch with common incoming line	5
art.253.xx	Two-way switch	6
art.254.xx	Two-way reversing (intermediate) switch	7
art.2511.xx	Single pole switch with pilot light	1
art.2521.xx	Two circuit switch with common incoming line and pilot light	5
art.2531.xx	Two-way switch with pilot light	6
art.2541.xx	Two-way reversing (intermediate) switch with pilot light	7
art.255.xx	Momentary contact switch (for luminaries)	1
art.255I.xx	Momentary contact switch with pilot light (for luminaries)	1
art.256.xx	Momentary contact switch (for bell)	1
art.256I.xx	Momentary contact switch with pilot light (for bell)	1
art.257.xx	Momentary contact switch (for blinds); combination of pattern No. 6 and 1	6 + 1

Explanation of color code .xx

00 - white

1A - gray with anthracite button

Additional information (if necessary)

Date: 2021-12-27

Signature: Bojan Pečavar

