

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Flush mounted Socket-outlet

Name and address of the applicant

ALING – CONEL d.o.o.
Železnička 10, 21432 Gajdobra, Serbia

Name and address of the manufacturer

ALING – CONEL d.o.o.
Železnička 10, 21432 Gajdobra, Serbia

Name and address of the factory

ALING – CONEL d.o.o.
Železnička 10, 21432 Gajdobra, Serbia*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2

16 A; 250 V~; IP44

Trademark / Brand (if any)

ALING - CONEL

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

art.623.xx; art.E623.xx

Additional information (if necessary may also be reported on page 2)

See the Test Report for information about National Differences.

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

T211-0853/25 (2025-09-22)

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Mašera-Spasičeva ulica 10, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services (SIST EN ISO/IEC 17065).

Date: 2025-09-22

Signature: Matej Žontar

Socket outlet art.623.xx is part of PRESTIGE family of products and art.E623.xx is part of EON family of products.

Explanation of colour codes (.xx):

First digit: code of covering frame colour (0 – white, 2 – graphite, 3 – dark red, 9 – beige, S - silver, E1 - soft black)

Second digit: code of interframe colour (0 – white, 2 – graphite, 3 – dark red, 9 – beige, S - silver, E1 - soft black)

Used combinations of codes for .xx: 00, 99, E1E1

Additional information (if necessary)

Date: 2025-09-22

Signature: Matej Žontar