

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Flush-mounting enclosure with incorporated terminals

Name and address of the applicant

ALING – CONEL d.o.o.
Železnička 10, 21432 Gajdobra, Serbia

Name and address of the manufacturer

ALING – CONEL d.o.o.
Železnička 10, 21432 Gajdobra, Serbia

Name and address of the factory

ALING – CONEL d.o.o.
Železnička 10, 21432 Gajdobra, Serbia*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2

16 A; 440 V~

Trademark / Brand (if any)

ALING - CONEL

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

art.640.x

Additional information (if necessary may also be reported on page 2)

See the Test Report for information about National Differences.

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-1:2015
IEC 60670-22:2003 + A1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

T211-0052/26 (2026-01-23)

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Mašera-Spasičeva ulica 10, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services (SIST EN ISO/IEC 17065).

Date: 2026-01-23

Signature: Matej Žontar

art.640.x is flush-mounted enclosure with incorporated terminals, where x represents the cover color code: x = 1 (white), 2 (graphite), 3 (dark red), 9 (beige), S (silver)

Additional information (if necessary)

This CB certificate replaces previously issued CB certificate SI-6753 issued on 2018-08-23 due to new test report.

Date: 2026-01-23

Signature: Matej Žontar